



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410  
PH (973) 636-9145 / FAX (973) 636-9144  
Email: info@envirovisionconsultants.com

CLIENT: Linden Public Schools  
PROJECT: Lead in Drinking Water  
ADDRESS: 10 Donaldson Pl, Linden, NJ 07036  
Field Technician: Jack Ruegg

Project Number 22-224  
Maintenance Building  
Report Date: June 30, 2022

As per your request, EnviroVision Consultants, Inc. was contracted by the Linden Public School District to conduct Lead (Pb) in drinking water sampling at the Maintenance Building on June 11, 2022. The sample locations, in addition to unique sample location codes were determined / assigned by school district personnel. The school district performed the proper flushing of the outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

The samples were analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey (NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Results: Three samples were collected from the Maintenance Building. In addition, a blank was collected and analyzed, as required, for Quality Assurance purposes.

All of the samples analyzed were either "None Detected" or below the United States Environmental Protection Agency (US EPA) threshold of 15 parts per billion (ppb) or ug/L for Lead in drinking water.

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,  
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager  
Attached: Lab results, associated data sheets



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Frederick Larson**  
**EnviroVision Consultants, Inc**  
**20-21 Wagaraw Rd**  
**Bldg 35E**  
**Fair Lawn, NJ 07410**

6/29/2022

Phone: (973) 636-9145

Fax: (973) 636-9144

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/15/2022. The results are tabulated on the attached data pages for the following client designated project:

**22-224 Linden Maintenance Facility**

The reference number for these samples is EMSL Order #012209535. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012209535  
 CustomerID: RAMA51  
 CustomerPO:  
 ProjectID:

Attn: **Frederick Larson**  
**EnviroVision Consultants, Inc**  
**20-21 Wagaraw Rd**  
**Bldg 35E**  
**Fair Lawn, NJ 07410**

Phone: (973) 636-9145  
 Fax: (973) 636-9144  
 Received: 6/15/2022 09:00 AM

Project: 22-224 Linden Maintenance Facility

**Analytical Results**

**Client Sample Description** MA-WC-01 **Collected:** 6/11/2022 **Lab ID:** 012209535-0001  
 Kitchen 12:20:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.22	1.00 µg/L	6/20/2022 VD	6/20/2022 JW 20:41

**Client Sample Description** MA-KS-02 **Collected:** 6/11/2022 **Lab ID:** 012209535-0002  
 Kitchen 12:20:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	6/20/2022 VD	6/20/2022 JW 20:43

**Client Sample Description** MA-IM-03 **Collected:** 6/11/2022 **Lab ID:** 012209535-0003  
 Kitchen 12:20:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	6/20/2022 VD	6/20/2022 JW 20:45

**Client Sample Description** MA-Blank **Collected:** 6/11/2022 **Lab ID:** 012209535-0004  
 12:24:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	6/20/2022 VD	6/20/2022 JW 20:47

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



EMSL ANALYTICAL, INC.  
TESTING LABS • PRODUCTS • TRAINING

**Lead Chain of Custody**

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

012209535

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

<b>Customer Information</b> Customer ID: RAMA51 Company Name: EnviroVision Consultants, Inc. Contact Name: Frederick Larson Street Address: 20-21 Wagaraw Rd, Bldg 35E City, State, Zip: Fair Lawn, NJ, 07410 Country: US Phone: 973-636-9145 Email(s) for Report: info@envirovisionconsultants.com	<b>Billing Information</b> Billing ID: RAMA51 Company Name: EnviroVision Consultants, Inc. Billing Contact: Frederick Larson Street Address: 20-21 Wagaraw Rd, Bldg 35E City, State, Zip: Fair Lawn, NJ, 07410 Country: US Phone: 973-636-9145 Email(s) for Invoice: info@envirovisionconsultants.com
--	--

<b>Project Information</b>	
Project Name/No: 22-224 Linden Maintenance Facility	Purchase Order: _____
EMSL LIMS Project ID (if applicable EMSL will provide)	US State where samples collected: _____ State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable)
Sampled By Name: Jack Ruegg	Sampled By Signature: <i>[Signature]</i> No. of Samples in Shipment: _____
Turn-Around-Time (TAT)	
<input type="checkbox"/> 3 Hour <input type="checkbox"/> 6 Hour <input type="checkbox"/> 24 Hour <input type="checkbox"/> 32 Hour <input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input type="checkbox"/> 1 Week <input checked="" type="checkbox"/> 2 Week	
Please call ahead for large projects and/or turnaround times 6 Hours or Less *32 Hour TAT available for select tests only, samples must be submitted by 11:30am	

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS <input type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/m <sup>2</sup> <small>*Reporting Limit based on a minimum 0.25g sample weight                      **Not appropriate for Ceramic Tiles - XRF is recommended</small>	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	0.0004% (4ppm)	<input type="checkbox"/>
	NIOSH 7082	Flame Atomic Absorption	4µg/liter	<input type="checkbox"/>
AIR	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter	<input type="checkbox"/>
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter	<input type="checkbox"/>
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM <small>*If no box is checked, non-ASTM Wipe is assumed</small>	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	1.0µg/wipe	<input type="checkbox"/>
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
TTLIC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
Wastewater Unpreserved <input type="checkbox"/> Preserved with HNO3 <input type="checkbox"/> PH<2	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Drinking Water Unpreserved <input checked="" type="checkbox"/> PH<2 Preserved with HNO3 <input type="checkbox"/> PH<2	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input checked="" type="checkbox"/>
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	<input type="checkbox"/>
Other:				<input type="checkbox"/>

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1 MA-WL-01	Kitchen	250mL	12:20 6/11/22
2 MA-KS-02	Kitchen	↓	12:20 ↓
3 MA-IM-03	kitchen	↓	12:20 ↓
4 MA-BLANK	<i>[Signature]</i>	↓	12:24 ↓

Method of Shipment:		Sample Condition Upon Receipt:	
Retinquished by: Jack Ruegg	Date/Time: 6/14/22	Received by: NIK Courier	Date/Time: 6/14/22 8:40pm
Retinquished by:	Date/Time:	Received by: <i>[Signature]</i>	Date/Time: 6/15/22 9m

Controlled Document - CDC-25 Lead R17 05/09/2022 \*6010C Available Upon Request

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.