



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : School #2: Linden #9099, 1700 South Wood Avenue, Linden NJ 07036

Matrix : Drinking Water

PAS Project ID : P25-00266

Report Date : 1/20/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-00266-01	SC2-0-WC-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:19	1/14/25 15:37
P25-00266-02	SC2-0-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:19	1/14/25 15:41
P25-00266-03	SC2-1-WC-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:21	1/14/25 15:45
P25-00266-04	SC2-1-BF-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:21	1/14/25 15:49
P25-00266-05	SC2-2-WC-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:24	1/14/25 16:02
P25-00266-06	SC2-2-BF-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:24	1/14/25 16:06
P25-00266-07	SC2-1-WC-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:26	1/14/25 16:10
P25-00266-08	SC2-1-BF-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:26	1/14/25 16:14
P25-00266-09	SC2-1-KS-11AA	Lead	1.19 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:29	1/14/25 16:18
P25-00266-10	SC2-1-KS-11BA	Lead	3.16	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:29	1/14/25 16:22
P25-00266-11	SC2-1-NS-28A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:32	1/14/25 16:26
P25-00266-12	SC2-1-WF-13A	Lead	2.72	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:34	1/14/25 16:30
P25-00266-13	SC2-1-WF-12A	Lead	2.07	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:34	1/14/25 16:34
P25-00266-14	SC2-1-TL-27A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:37	1/14/25 18:06
P25-00266-15	SC2-1-WF-26AA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:43	1/14/25 18:10
P25-00266-16	SC2-1-WF-26BA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:44	1/14/25 18:14
P25-00266-17	SC2-1-DW-23A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:46	1/14/25 18:18
P25-00266-18	SC2-1-DW-22A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:47	1/14/25 18:22
P25-00266-19	SC2-1-DW-21A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:49	1/14/25 18:38
P25-00266-20	SC2-1-DW-18A	Lead	2.07	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:50	1/14/25 18:50
P25-00266-21	SC2-1-DW-17A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:52	1/14/25 18:54
P25-00266-22	SC2-1-DW-16A	Lead	0.970 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:53	1/14/25 18:59
P25-00266-23	SC2-2-WF-40AA	Lead	1.41 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:56	1/14/25 19:03
P25-00266-24	SC2-2-WF-40BA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:57	1/14/25 19:07
P25-00266-25	SC2-2-DW-39A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 08:59	1/14/25 19:11
P25-00266-26	SC2-2-DW-38A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 09:00	1/14/25 19:15
P25-00266-27	SC2-2-DW-37A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 09:02	1/14/25 19:19
P25-00266-28	SC2-2-DW-36A	Lead	0.970 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 09:03	1/14/25 19:23
P25-00266-29	SC2-2-DW-35A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 09:04	1/14/25 19:35
P25-00266-30	SC2-2-DW-34A	Lead	1.63 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 09:06	1/14/25 19:39
P25-00266-31	SC2-2-DW-32A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 09:08	1/14/25 19:43
P25-00266-32	SC2-2-DW-29A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 09:09	1/14/25 19:47
P25-00266-33	SC2-12-31-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/31/24 09:10	1/14/25 19:51

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer



part of
ALS Limited

**CHAIN
OF
CUSTODY**

Customer: Garden State Environmental
 Address: 555 S. Broad St.
 Glen Rock, NJ 07452
 Phone: (201) 652-1119 Office

School Name: School #2 : Linden #9099
 School Address: 1700 South Wood Avenue, Linden, New Jersey 07036
 Sampled By: Frank Obando
 Print Name: Frank Obando
 RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: 12 / 31 / 24 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Fiber Protect	# Containers	Glass or Plastic	Analysis	LAB ID
Near RM B-4 SC2-0-WC-01A	8:19 AM	DW	Grab			1	250 ml Plastic	Lead	P25-00266-1
Near RM B-4 SC2-0-BF-01A	8:19 AM	DW	Grab		X	1	250 ml Plastic	Lead	-02
Near RM 109B SC2-1-WC-02A	8:21 AM	DW	Grab			1	250 ml Plastic	Lead	-03
Near RM 109B SC2-1-BF-02A	8:21 AM	DW	Grab		X	1	250 ml Plastic	Lead	-04
Near RM 209B SC2-2-WC-03A	8:24 AM	DW	Grab			1	250 ml Plastic	Lead	-05
Near RM 209B SC2-2-BF-03A	8:24 AM	DW	Grab		X	1	250 ml Plastic	Lead	-06
Near RM 111C SC2-1-WC-04A	8:26 AM	DW	Grab			1	250 ml Plastic	Lead	-07
Near RM 111C SC2-1-BF-04A	8:26 AM	DW	Grab		X	1	250 ml Plastic	Lead	-08
Kitchen 3 Comp, (L) SC2-1-KS-11AA	8:29 AM	DW	Grab			1	250 ml Plastic	Lead	-09
Kitchen 3 Comp, (R) SC2-1-KS-11BA	8:29 AM	DW	Grab			1	250 ml Plastic	Lead	-10
Nurse's Office SC2-1-NS-28A	8:32 AM	DW	Grab			1	250 ml Plastic	Lead	-11
Near Exit Door #17, (L) SC2-1-WF-13A	8:34 AM	DW	Grab			1	250 ml Plastic	Lead	-12
Near Exit Door #17, (R) SC2-1-WF-12A	8:34 AM	DW	Grab			1	250 ml Plastic	Lead	-13
Faculty RM 115D SC2-1-TL-27A	8:37 AM	DW	Grab			1	250 ml Plastic	Lead	-14
Next to RM 115D, (R) SC2-1-WF-26AA	8:43 AM	DW	Grab			1	250 ml Plastic	Lead	P25-00266-15

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Deliverables: PDF Std. X PDF Reduce Full EDD Date/Time Preserved with WDOs: 1/9/25 @ 1145

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Frank Obando	Frank Obando	GSE	1/2/25 + 10:30 AM
Received:	Kerry Hodges	[Signature]	GSE	1/8/25 1155
Relinquished:	Kerry Hodges	[Signature]	YAL	1/8/25 1755
Received:	Lauren Palumbo	[Signature]		
Relinquished:				
Received:				

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: School #2
School Address: 1700 South Wood Avenue, Linden, New Jersey 07036
Sampled By: Frank Obando
Print Name: Frank Obando
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date: M / D / 24 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
Next to RM 115D, (L) SC2-1-WF-26BA	8:44 AM	DW	Grab			1	250 ml Plastic	Lead	P25-00266-16
Room 102D SC2-1-DW-23A	8:46 AM	DW	Grab			1	250 ml Plastic	Lead	-17
Room 104D SC2-1-DW-22A	8:47 AM	DW	Grab			1	250 ml Plastic	Lead	-18
Room 106D SC2-1-DW-21A	8:49 AM	DW	Grab			1	250 ml Plastic	Lead	-19
Room 112D SC2-1-DW-18A	8:50 AM	DW	Grab			1	250 ml Plastic	Lead	-20
Room 111D SC2-1-DW-17A	8:52 AM	DW	Grab			1	250 ml Plastic	Lead	-21
Room 109D SC2-1-DW-16A	8:53 AM	DW	Grab			1	250 ml Plastic	Lead	-22
Across RM 214D, (R) SC2-2-WF-40AA	8:56 AM	DW	Grab			1	250 ml Plastic	Lead	-23
Across RM 214D, (L) SC2-2-WF-40BA	8:57 AM	DW	Grab			1	250 ml Plastic	Lead	-24
Room 207D SC2-2-DW-39A	8:59 AM	DW	Grab			1	250 ml Plastic	Lead	-25
Room 205D SC2-2-DW-38A	9:00 AM	DW	Grab			1	250 ml Plastic	Lead	-26
Room 203D SC2-2-DW-37A	9:02 AM	DW	Grab			1	250 ml Plastic	Lead	-27
Room 202D SC2-2-DW-36A	9:03 AM	DW	Grab			1	250 ml Plastic	Lead	-28
Room 204D SC2-2-DW-35A	9:04 AM	DW	Grab			1	250 ml Plastic	Lead	-29
Room 206D SC2-2-DW-34A	9:06 AM	DW	Grab			1	250 ml Plastic	Lead	P25-00266-30

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Deliverables: PDF Std. PDF Reduce PDF Full EDD Date/Time Preserved with HNO3: 1/9/25 @ 1145

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Frank Obando	Frank Obando	GSE	1/2/25 + 10:30 AM
Received:	<i>Frank Obando</i>	<i>Frank Obando</i>	<i>GSE</i>	<i>1/8/25 1155</i>
Relinquished:	<i>Terry Hedges</i>	<i>Terry Hedges</i>	<i>GSE</i>	<i>1/8/25 1755</i>
Received:	<i>Lauren Palumbo</i>	<i>Lauren Palumbo</i>	<i>YAL</i>	
Relinquished:				
Received:				

