



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
PH (973) 636-9145 / FAX (973) 636-9144
Email: info@envirovisionconsultants.com

CLIENT: Linden School District

Project Number 22-224

PROJECT: Lead in Drinking Water

School Number 4

ADDRESS: 1602 Dill Ave, Linden NJ 07036

Report Date: July 5, 2022

Field Technician: Jordan Pryske

As per your request, EnviroVision Consultants, Inc. was contracted by the Linden Public School District to conduct Lead (Pb) in water sampling at School Number 4 on June 11, 2022. The sample locations, in addition to unique sample location codes were determined/assigned by school district personnel. The school district performed the proper flushing of outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

The samples were analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey *(NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Twenty-eight samples were collected from School Number 4. In addition, a sample was collected and analyzed, as required, for Quality Assurance purposes.

Results: Twenty-six of the samples analyzed were either "None Detected" or less than the EPA established threshold for lead in drinking water. However, two of the samples were above the allowable limit established by The United States Environmental Protection Agency (USEPA) of 15 parts per billion (ppb) or ug/L. When a water outlet/faucet meets or exceeds the USEPA threshold, EnviroVision recommends that the outlet/faucet be put out of service until the system can be further evaluated and proper remedial action is achieved.



SCHOOL NUMBER 4 - LEAD(Pb) in Water Result(s) of Concern

Outlet ID/Sample Number	Location	Results
SC4-FP-20	Kitchen(sink)	18.8 ppb, ug/L
SC4-WF-24	Outside Office (Fountain)	18.4 ppb, ug/L

Note* 1ppb = 1ug/L

Due to the elevated level in the above-mentioned outlet, we recommend that some or all of the following steps be taken at this time.

- Closure of the affected water outlet(s) until the system can be further evaluated and proper remedial action is achieved.
- Removal and replacement with non-lead containing fixtures.
- Installation of filtration systems.
- Development of a Flushing Program for those taps high in lead and turbidity (this may include automatic flushing systems).
- Contact the local water utility company to obtain information about their corrosion control procedures and how it might affect the District's control plans.
- Permanent closure of outlet(s).

Once the remedial action(s) are complete, follow up testing is required to ensure alterations/replacement to plumbing fixtures has lowered the amount of lead to acceptable levels.

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager
Attached: Lab results, associated data sheets



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

7/1/2022

Phone: (973) 636-9145

Fax: (973) 636-9144

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/15/2022. The results are tabulated on the attached data pages for the following client designated project:

22-224 Linden School #4

The reference number for these samples is EMSL Order #012209447. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012209447
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 6/15/2022 09:00 AM

Project: 22-224 Linden School #4

Analytical Results

Client Sample Description 01 SC4-DW-01 **Collected:** 6/4/2022 **Lab ID:** 012209447-0001
 Room 30 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.13	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:30

Client Sample Description 02 SC4-DW-02 **Collected:** 6/4/2022 **Lab ID:** 012209447-0002
 Room 29 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:35

Client Sample Description 03 SC4-DW-03 **Collected:** 6/4/2022 **Lab ID:** 012209447-0003
 Room 27 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:37

Client Sample Description 04 SC4-DW-04 **Collected:** 6/4/2022 **Lab ID:** 012209447-0004
 Room 25 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:38

Client Sample Description 05 SC4-DW-05 **Collected:** 6/4/2022 **Lab ID:** 012209447-0005
 Room 23 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:43

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012209447
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 6/15/2022 09:00 AM

Project: 22-224 Linden School #4

Analytical Results

Client Sample Description 06 SC4-DW-06 **Collected:** 6/4/2022 **Lab ID:** 012209447-0006
 Room 21 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:44

Client Sample Description 07 SC4-DW-07 **Collected:** 6/4/2022 **Lab ID:** 012209447-0007
 Room 19 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:46

Client Sample Description 08 SC4-DW-08 **Collected:** 6/4/2022 **Lab ID:** 012209447-0008
 Room 18 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.39	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:47

Client Sample Description 09 SC4-DW-09 **Collected:** 6/4/2022 **Lab ID:** 012209447-0009
 Room 20 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:49

Client Sample Description 10 SC4-DW-10 **Collected:** 6/4/2022 **Lab ID:** 012209447-0010
 Room 26 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:51

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012209447

CustomerID: RAMA51

CustomerPO:

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 6/15/2022 09:00 AM

Project: 22-224 Linden School #4

Analytical Results

Client Sample Description 11 SC4-DW-11
 Room 28 (Fountain) **Collected:** 6/4/2022 **Lab ID:** 012209447-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.29	1.00 µg/L	6/28/2022 KG	6/30/2022 KG 08:52

Client Sample Description 12 SC4-DW-12
 Room 1 (Fountain) **Collected:** 6/4/2022 **Lab ID:** 012209447-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.26	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 18:47

Client Sample Description 13 SC4-DW-13
 Room 3 (Fountain) **Collected:** 6/4/2022 **Lab ID:** 012209447-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.49	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 18:49

Client Sample Description 14 SC4-WF-14
 Hallway by Room 10 (Fountain) **Collected:** 6/4/2022 **Lab ID:** 012209447-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.35	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 18:50

Client Sample Description 15 SC4-WF-15
 Hallway by Room 12 (Fountain) **Collected:** 6/4/2022 **Lab ID:** 012209447-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.63	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 18:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012209447
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 6/15/2022 09:00 AM

Project: 22-224 Linden School #4

Analytical Results

Client Sample Description 16 SC4-WF-16
 Hallway by Room 14 (Fountain) **Collected:** 6/4/2022 **Lab ID:** 012209447-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.49	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 18:53

Client Sample Description 17 SC4-WC-17-U
 Outside gym (Upper Water Cooler) **Collected:** 6/4/2022 **Lab ID:** 012209447-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 18:55

Client Sample Description 18 SC4-WC-17-L
 Outside gym (Lower Water Cooler) **Collected:** 6/4/2022 **Lab ID:** 012209447-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 18:57

Client Sample Description 19 SC4-WF-18
 Outside Bathrooms (Fountain) **Collected:** 6/4/2022 **Lab ID:** 012209447-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.1	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 18:58

Client Sample Description 20 SC4-KS-19
 Kitchen (Sink) **Collected:** 6/4/2022 **Lab ID:** 012209447-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.11	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 19:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012209447

CustomerID: RAMA51

CustomerPO:

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 6/15/2022 09:00 AM

Project: 22-224 Linden School #4

Analytical Results

Client Sample Description 21 SC4-FP-20 **Collected:** 6/4/2022 **Lab ID:** 012209447-0021
 Kitchen (Sink)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.8	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 03:47

Client Sample Description 22 SC4-TL-21 **Collected:** 6/4/2022 **Lab ID:** 012209447-0022
 Teacher's Lounge (Sink)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.54	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 03:52

Client Sample Description 23 SC4-DW-22 **Collected:** 6/4/2022 **Lab ID:** 012209447-0023
 Room 7 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 03:56

Client Sample Description 24 SC4-DW-23 **Collected:** 6/4/2022 **Lab ID:** 012209447-0024
 Room 6 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 03:58

Client Sample Description 25 SC4-WF-24 **Collected:** 6/4/2022 **Lab ID:** 012209447-0025
 Outside Office (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	34.5	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 03:59

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012209447
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 6/15/2022 09:00 AM

Project: 22-224 Linden School #4

Analytical Results

Client Sample Description 26 SC4-W5-25 **Collected:** 6/4/2022 **Lab ID:** 012209447-0026
 Nurse Room (Sink)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.20	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 04:01

Client Sample Description 27 SC4-DW-26 **Collected:** 6/4/2022 **Lab ID:** 012209447-0027
 Room 4 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.01	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 04:03

Client Sample Description 28 SC4-DW-27 **Collected:** 6/4/2022 **Lab ID:** 012209447-0028
 Room 2 (Fountain)

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.28	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 04:04

Client Sample Description 29 SC4-BLANK **Collected:** 6/4/2022 **Lab ID:** 012209447-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2022 KG	6/29/2022 KG 04:06

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results

PL 6/29/22 JD



Lead Chain of Custody
EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

012209447

PHONE: (800) 220-3875

EMAIL: CinnaminsonLeadLab@emsl.com

Customer Information		Billing Information	
Customer ID: RAMA51	Company Name: EnviroVision Consultants, Inc.	Billing ID: RAMA51	Company Name: EnviroVision Consultants, Inc.
Contact Name: Frederick Larson	Street Address: 20-21 Wagaraw Rd, Bldg 35E	Billing Contact: Frederick Larson	Street Address: 20-21 Wagaraw Rd, Bldg 35E
City, State, Zip: Fair Lawn, NJ, 07410	Country: US	City, State, Zip: Fair Lawn, NJ, 07410	Country: US
Phone: 973-636-9145		Phone: 973-636-9145	
Email(s) for Report: info@envirovisionconsultants.com		Email(s) for Invoice: info@envirovisionconsultants.com	

Project Information

Project Name/No: 22-224 Linden School #4

EMSL LIMS Project ID (if applicable, EMSL will provide)

US State where samples collected: NJ

State of Connecticut (CT) must select project location: Commercial (Taxable) Residential (Non-Taxable)

Sampled By Name: Jordan Pysko

Sampled By Signature: [Signature]

No. of Samples in Shipment

Turn-Around-Time (TAT)

3 Hour 6 Hour 24 Hour 32 Hour 48 Hour 72 Hour 96 Hour 1 Week 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less *32 Hour TAT available for select tests only, samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS <input type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/cm ² *Reporting Limit based on a minimum 0.25g sample weight. **Not appropriate for Ceramic Tiles - XRF is recommended	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	0.0004% (4ppm)	<input type="checkbox"/>
	NIOSH 7082	Flame Atomic Absorption	4µg/liter	<input type="checkbox"/>
AIR	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/liter	<input type="checkbox"/>
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/liter	<input type="checkbox"/>
	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM *If no box is checked, non-ASTM Wipe is assumed	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	1.0µg/wipe	<input type="checkbox"/>
TCPL	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
Wastewater Unpreserved <input type="checkbox"/> PH<2	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Drinking Water Unpreserved <input checked="" type="checkbox"/> PH<2	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input checked="" type="checkbox"/>
Preserved with HNO3 <input type="checkbox"/> PH<2	40 CFR Part 50	ICP-OES	12 µg/liter	<input type="checkbox"/>
TSP/SPM Filter				<input type="checkbox"/>
Other:				<input type="checkbox"/>

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1 SCH-DW-01	Room 30 (Fountain)	250ml	6/11/22 0804
2 SCH-DW-02	Room 29 (Fountain)	↓	6/11/22 0806
3 SCH-DW-03	Room 27 (Fountain)		6/11/22 0807
4 SCH-DW-04	Room 25 (Fountain)		6/11/22 0809
5 SCH-DW-05	Room 23 (Fountain)		6/11/22 0811

Method of Shipment

Sample Condition Upon Receipt

Relinquished by: J. Pysko

Date/Time: [Blank]

Received by: NW COURTESY

Date/Time: 6/14/22 8:40am

Relinquished by: [Blank]

Date/Time: [Blank]

Received by: [Signature]

Date/Time: 6/15/22 9am

Controlled Document - CQC-25 Lead R17 05/09/2022

*5010C Available Upon Request

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

HNO₃ added 6/15/22 7:55 of [Signature]

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Pb 6/19/22 JD



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

012209447

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
6	SCH-DW-06 Room 21 (Fountain)	250 mL	6/11/22 0813
7	SCH-DW-07 Room 19 (Fountain)		6/11/22 0814
8	SCH-DW-08 Room 18 (Fountain)		6/11/22 0815
9	SCH-DW-09 Room 20 (Fountain)		6/11/22 0820
10	SCH-DW-10 Room 26 (Fountain)		6/11/22 0826
11	SCH-DW-11 Room 28 (Fountain)		6/11/22 0828
12	SCH-DW-12 Room 1 (Fountain)		6/11/22 0830
13	SCH-DW-13 Room 3 (Fountain)		6/11/22 0832
14	SCH-WF-14 Hallway by Room 10 (Fountain)		6/11/22 0836
15	SCH-WF-15 Hallway by Room 12 (Fountain)		6/11/22 0838
16	SCH-WF-16 Hallway by Room 14 (Fountain)		6/11/22 0840
17	SCH-WC-17-U Outside gym (Upper water cooler)		6/11/22 0843
18	SCH-WC-17-L Outside gym (Lower water cooler)		6/11/22 0844
19	SCH-WF-18 Outside Bathrooms (Fountain)		6/11/22 0845
20	SCH-KS-19 Kitchen (Sink)		6/11/22 0847
21	SCH-FP-20 Kitchen (Sink)		6/11/22 0848
22	SCH-TL-21 Teachers Lounge (Sink)		6/11/22 0851
23	SCH-DW-22 Room 7 (Fountain)		6/11/22 0853
24	SCH-DW-23 Room 6 (Fountain)		6/11/22 0855
25	SCH-WF-24 Outside office (Fountain)		6/11/22 0857
26	SCH-NS-25 Nurse Room (Sink)		6/11/22 0859
27	SCH-DW-26 Room 4 (Fountain)		6/11/22 0900
28	SCH-DW-27 Room 2 (Fountain)		6/11/22 0904
29	SCH-BLANK		6/11/22 0905

RECEIVED

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by: J. Pyszko	Date/Time:	Received by: AN courier	Date/Time: 6/14/22 8:40am
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document - COC-25 Lead R17 05/09/2022

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.