



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
PH (973) 636-9145 / FAX (973) 636-9144
Email: info@envirovisionconsultants.com

CLIENT: Linden Public Schools
PROJECT: Lead in Drinking Water
ADDRESS: 121 W. St. Georges Ave, Linden, NJ 07036
Field Technician: Leonardo Bitondo

Project Number 22-224
Linden High School

Report Date: June 30, 2022

As per your request, EnviroVision Consultants, Inc. was contracted by the Linden Public School District to conduct Lead (Pb) in drinking water sampling at the Linden High School on June 11, 2022. The sample locations, in addition to unique sample location codes were determined / assigned by school district personnel. The school district performed the proper flushing of the outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

The samples were analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey (NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Results: Thirty-six samples were collected from the Linden High School. In addition, a blank sample was collected and analyzed, as required, for Quality Assurance purposes.

All of the samples analyzed were either "None Detected" or below the United States Environmental Protection Agency threshold of 15 parts per billion (ppb) or ug/L.

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager
Attached: Lab results, associated data sheets



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Frederick Larson
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410**

6/30/2022

Phone: (973) 636-9145

Fax: (973) 636-9144

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/15/2022. The results are tabulated on the attached data pages for the following client designated project:

22-224 Linden High School

The reference number for these samples is EMSL Order #012209434. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012209434

CustomerID: RAMA51

CustomerPO:

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145

Fax: (973) 636-9144

Received: 06/15/22 9:00 AM

Project: 22-224 Linden High School

Analytical Results

Client Sample Description	01 HSWCO1 Across Room 106	Collected:	6/4/2022 7:59:00 AM	Lab ID:	012209434-0001
----------------------------------	------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 3:56 VD

Client Sample Description	02 HSEC2 Room 102	Collected:	6/4/2022 8:00:00 AM	Lab ID:	012209434-0002
----------------------------------	----------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:01 VD

Client Sample Description	03 HSWC3BF Across Room 101	Collected:	6/4/2022 8:01:00 AM	Lab ID:	012209434-0003
----------------------------------	-------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:02 VD

Client Sample Description	04 HSWC3F Across Room 101	Collected:	6/4/2022 8:02:00 AM	Lab ID:	012209434-0004
----------------------------------	------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:04 VD

Client Sample Description	05 HSWC4 Teacher Cafeteria	Collected:	6/4/2022 8:03:00 AM	Lab ID:	012209434-0005
----------------------------------	-------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:08 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012209434

CustomerID: RAMA51

CustomerPO:

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 06/15/22 9:00 AM

Project: 22-224 Linden High School

Analytical Results

Client Sample Description 06 HSWE5
Hallway Room 111
Collected: 6/4/2022 8:10:00 AM
Lab ID: 012209434-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:10 VD

Client Sample Description 07 HSWE6
Gym Lobby
Collected: 6/4/2022 8:11:00 AM
Lab ID: 012209434-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.22	1.00 µg/L	6/23/2022 KG	06/24/22 4:12 VD

Client Sample Description 08 HSS7
Weight Room
Collected: 6/4/2022 8:12:00 AM
Lab ID: 012209434-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.16	1.00 µg/L	6/23/2022 KG	06/24/22 4:13 VD

Client Sample Description 09 HSIm8
Weight Room
Collected: 6/4/2022 8:14:00 AM
Lab ID: 012209434-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:15 VD

Client Sample Description 10 HSIm11
Kitchen
Collected: 6/4/2022 8:16:00 AM
Lab ID: 012209434-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:16 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012209434

CustomerID: RAMA51

CustomerPO:

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 06/15/22 9:00 AM

Project: 22-224 Linden High School

Analytical Results

Client Sample Description		11 HSFP12 Kitchen	Collected:	6/4/2022 8:17:00 AM	Lab ID:	012209434-0011	
Method	Parameter		Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Lead		1.41	1.00 µg/L	6/23/2022	KG	06/24/22 4:18 VD
Client Sample Description		12 HSKS 14 Kitchen	Collected:	6/4/2022 8:18:00 AM	Lab ID:	012209434-0012	
Method	Parameter		Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Lead		ND	1.00 µg/L	6/23/2022	KG	06/24/22 4:22 VD
Client Sample Description		13 HSFP15 Kitchen	Collected:	6/4/2022 8:19:00 AM	Lab ID:	012209434-0013	
Method	Parameter		Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Lead		6.01	1.00 µg/L	6/23/2022	KG	06/24/22 4:27 VD
Client Sample Description		14 HSCT16 Kitchen	Collected:	6/4/2022 8:20:00 AM	Lab ID:	012209434-0014	
Method	Parameter		Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Lead		2.01	1.00 µg/L	6/23/2022	KG	06/24/22 4:29 VD
Client Sample Description		15 HSCT17 Kitchen	Collected:	6/4/2022 8:22:00 AM	Lab ID:	012209434-0015	
Method	Parameter		Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Lead		6.21	1.00 µg/L	6/23/2022	KG	06/24/22 4:30 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012209434

CustomerID: RAMA51

CustomerPO:

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145

Fax: (973) 636-9144

Received: 06/15/22 9:00 AM

Project: 22-224 Linden High School

Analytical Results

Client Sample Description 16 HSFP18
Kitchen

Collected: 6/4/2022
8:25:00 AM

Lab ID: 012209434-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.00	1.00 µg/L	6/23/2022 KG	06/24/22 4:32 VD

Client Sample Description 17 HSFP19
Serving Line

Collected: 6/4/2022
8:26:00 AM

Lab ID: 012209434-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:33 VD

Client Sample Description 18 HSWCBF20
Cafeteria A

Collected: 6/4/2022
8:27:00 AM

Lab ID: 012209434-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:35 VD

Client Sample Description 19 HSWCF20
Cafeteria A

Collected: 6/4/2022
8:29:00 AM

Lab ID: 012209434-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:36 VD

Client Sample Description 20 HSWCBF21
Cafeteria B

Collected: 6/4/2022
8:31:00 AM

Lab ID: 012209434-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 4:38 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012209434

CustomerID: RAMA51

CustomerPO:

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 06/15/22 9:00 AM

Project: 22-224 Linden High School

Analytical Results

Client Sample Description		21 HSWCF21 Cafeteria B	Collected:	6/4/2022 8:34:00 AM	Lab ID:	012209434-0021	
Method	Parameter		Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Lead		ND	1.00 µg/L	6/23/2022	KG	06/24/22 3:08 VD
Client Sample Description		22 HSWC 22 Outside Up office	Collected:	6/4/2022 8:36:00 AM	Lab ID:	012209434-0022	
Method	Parameter		Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Lead		3.66	1.00 µg/L	6/23/2022	KG	06/24/22 3:16 VD
Client Sample Description		23 HSWC 23 Outside Guidance	Collected:	6/4/2022 8:37:00 AM	Lab ID:	012209434-0023	
Method	Parameter		Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Lead		ND	1.00 µg/L	6/23/2022	KG	06/24/22 3:17 VD
Client Sample Description		24 HSNS 24 Nurse Room	Collected:	6/4/2022 8:44:00 AM	Lab ID:	012209434-0024	
Method	Parameter		Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Lead		1.45	1.00 µg/L	6/23/2022	KG	06/24/22 3:19 VD
Client Sample Description		25 HSNS 25 Nurse Room	Collected:	6/4/2022 8:45:00 AM	Lab ID:	012209434-0025	
Method	Parameter		Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Lead		ND	1.00 µg/L	6/23/2022	KG	06/24/22 3:20 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012209434

CustomerID: RAMA51

CustomerPO:

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145

Fax: (973) 636-9144

Received: 06/15/22 9:00 AM

Project: 22-224 Linden High School

Analytical Results

Client Sample Description	26 HSNC 30 Outside Up 2nd Floor	Collected:	6/4/2022 8:50:00 AM	Lab ID:	012209434-0026
----------------------------------	------------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
---------------	------------------	---------------	-----------------	------------------------------------	--

METALS

200.8	Lead	7.48	1.00 µg/L	6/23/2022 KG	06/24/22 3:22 VD
-------	------	------	-----------	--------------	------------------

Client Sample Description	27 HSS31 Media Center	Collected:	6/4/2022 8:52:00 AM	Lab ID:	012209434-0027
----------------------------------	--------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
---------------	------------------	---------------	-----------------	------------------------------------	--

METALS

200.8	Lead	1.62	1.00 µg/L	6/23/2022 KG	06/24/22 3:23 VD
-------	------	------	-----------	--------------	------------------

Client Sample Description	28 HSWC32 Outside Room 306	Collected:	6/4/2022 8:56:00 AM	Lab ID:	012209434-0028
----------------------------------	-------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
---------------	------------------	---------------	-----------------	------------------------------------	--

METALS

200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 3:25 VD
-------	------	----	-----------	--------------	------------------

Client Sample Description	29 HSWCBF33 Outside Room 305	Collected:	6/4/2022 9:00:00 AM	Lab ID:	012209434-0029
----------------------------------	---------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
---------------	------------------	---------------	-----------------	------------------------------------	--

METALS

200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 3:27 VD
-------	------	----	-----------	--------------	------------------

Client Sample Description	30 HSWCF33 Outside Room 305	Collected:	6/4/2022 9:01:00 AM	Lab ID:	012209434-0030
----------------------------------	--------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
---------------	------------------	---------------	-----------------	------------------------------------	--

METALS

200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 3:31 VD
-------	------	----	-----------	--------------	------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012209434

CustomerID: RAMA51

CustomerPO:

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 06/15/22 9:00 AM

Project: 22-224 Linden High School

Analytical Results

Client Sample Description		31 HSWF34 Next to Room 311	Collected:		6/4/2022 9:03:00 AM	Lab ID:		012209434-0031	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		10.5	1.00 µg/L		6/23/2022	KG	06/24/22 3:33	VD
Client Sample Description		32 HSWC35 Faculty Room 3rd Floor	Collected:		6/4/2022 9:05:00 AM	Lab ID:		012209434-0032	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		6/23/2022	KG	06/24/22 3:37	VD
Client Sample Description		33 HSWE36 Across Room 317	Collected:		6/4/2022 9:06:00 AM	Lab ID:		012209434-0033	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		10.6	1.00 µg/L		6/23/2022	KG	06/24/22 3:39	VD
Client Sample Description		34 HSWC37 Next to Room 312	Collected:		6/4/2022 9:08:00 AM	Lab ID:		012209434-0034	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		2.63	1.00 µg/L		6/23/2022	KG	06/24/22 3:41	VD
Client Sample Description		35 HSWCBF26 Outside Office	Collected:		6/4/2022 8:47:00 AM	Lab ID:		012209434-0035	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead		ND	1.00 µg/L		6/23/2022	KG	06/24/22 3:42	VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012209434

CustomerID: RAMA51

CustomerPO:

ProjectID:

Attn: **Frederick Larson**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
Fax: (973) 636-9144
Received: 06/15/22 9:00 AM

Project: 22-224 Linden High School

Analytical Results

Client Sample Description	36 HSWCF26 Outside Office	Collected:	6/4/2022 8:48:00 AM	Lab ID:	012209434-0036
----------------------------------	------------------------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 3:44 VD

Client Sample Description	37 HS BLANK	Collected:	6/4/2022 9:12:00 AM	Lab ID:	012209434-0037
----------------------------------	-------------	-------------------	------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/23/2022 KG	06/24/22 3:45 VD

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results


EMSL ANALYTICAL, INC.
 TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

612209434

Pb 6/29/22 JD

 EMSL Analytical, Inc.
 200 Route 130 North
 Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Customer Information Customer ID: RAMA51 Company Name: EnviroVision Consultants, Inc. Contact Name: Frederick Larson Street Address: 20-21 Wagaraw Rd, Bldg 35E City, State, Zip: Fair Lawn, NJ, 07410 Country: US Phone: 973-636-9145 Email(s) for Report: info@envirovisionconsultants.com		Billing Information Billing ID: RAMA51 Company Name: EnviroVision Consultants, Inc. Billing Contact: Frederick Larson Street Address: 20-21 Wagaraw Rd, Bldg 35E City, State, Zip: Fair Lawn, NJ, 07410 Country: US Phone: 973-636-9145 Email(s) for Invoice: info@envirovisionconsultants.com	
Project Information Project Name/No: 22-224 Linden High School EMSL LIMS Project ID: (If applicable, EMSL will provide) US State where samples collected: ☐ Connecticut (CT) must select project location: Commercial (Taxable) ☐ Residential (Non-Taxable) ☐			
Sampled By Name: <i>Leah Taro</i> Sampled By Signature: <i>[Signature]</i>		No. of Samples in Shipment:	
Turn-Around-Time (TAT) ☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☒ 2 Week Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only, samples must be submitted by 11:30am.			
MATRIX CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/l or *Reporting Limit based on a minimum 0.25g sample weight. **Not appropriate for Ceramic Tiles - XRF is recommended.	METHOD SW 846-7000B SW 846-6010D* NIOSH 7082 NIOSH 7300M / NIOSH 7303M NIOSH 7300M / NIOSH 7303M	INSTRUMENT Flame Atomic Absorption ICP-OES Flame Atomic Absorption ICP-OES ICP-MS	REPORTING LIMIT 0.008% (80ppm) 0.0004% (4ppm) 4µg/filter 0.5µg/filter 0.05µg/filter
SELECTION ☐	☐		
AIR Wipe ☐ ASTM ☐ NON-ASTM *If no box is checked, non-ASTM Wipe is assumed.	SW 846-7000B SW 846-6010D*	Flame Atomic Absorption ICP-OES	10µg/wipe 1 0µg/wipe
☐	☐		
TCLP	SW 846-1311 / 7000B / SM 3111B SW 846-1311 / SW 846-6010D* SW 846-1312 / 7000B / SM 3111B SW 846-1312 / SW 846-6010D*	Flame Atomic Absorption ICP-OES Flame Atomic Absorption ICP-OES	0.4 mg/L (ppm) 0.1 mg/L (ppm) 0.4 mg/L (ppm) 0.1 mg/L (ppm)
☐	☐		
SPFP	22 CCR App. II, 7000B 22 CCR App. II, SW 846-6010D*	Flame Atomic Absorption ICP-OES	40mg/kg (ppm) 2mg/kg (ppm)
☐	☐		
ITLC	22 CCR App. II, 7000B 22 CCR App. II, SW 846-6010D*	Flame Atomic Absorption ICP-OES	0.4 mg/L (ppm) 0.1 mg/L (ppm)
☐	☐		
STLC	SW 846-7000B SW 846-6010D* SM 3111B / SW 846-7000B	Flame Atomic Absorption ICP-OES Flame Atomic Absorption	40mg/kg (ppm) 2mg/kg (ppm) 0.4 mg/L (ppm)
☐	☐		
Soil	EPA 200.7 EPA 200.5 EPA 200.8 40 CFR Part 50	ICP-OES ICP-OES ICP-MS ICP-OES	0.020 mg/L (ppm) 0.003 mg/L (ppm) 0.001 mg/L (ppm) 12 µg/filter
☐	☐		
Wastewater Unpreserved ☐ Preserved with HNO3 ☐ PH<2 Drinking Water Unpreserved ☒ Preserved with HNO3 ☐ PH<2	Other:		
TSP/SPM Filter	Other:		
Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1 HSWC01	Across Room 106	256 mL	6/14/22 759
2 HSECO2	Across Room 106	250 mL	800
3 ASWCO3BF	Across Room 101	↓	801
4 HSWCO3F	Across Room 101	↓	802
5 HSWCO4	Teacher Cafeteria	↓	803
Method of Shipment			
Relinquished by: <i>[Signature]</i> Date/Time: 6/11/22	Relinquished by: <i>[Signature]</i> Date/Time: 6/11/22	Received by: <i>[Signature]</i> COXIER Date/Time: 6/14/22 8:40pm	Received by: <i>[Signature]</i> Elynn Date/Time: 6/15/22 9am

Controlled Document - COC-25 Lead R17 05/09/2022

*6010C Available Upon Request

☒ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Page 1 of 2

HAKL called in house 11:30AM 6/15/22 JD

Pb 6/24/2250

EMSL

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.

200 Route 130 North

Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

012209434

PHONE (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

High School

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
6 HSW E05	Hallway Rm 111	250ml	6/11/22 810
7 HSW E06	Gym Lobby		811
8 HSS07	Weight Room	250	812
9 HSTim08	Weight Room		814
10 HSTim 11	Kitchen		816
11 HSFPI2	Kitchen		817
12 HSKS14	Kitchen		818
13 HSFPI5	Kitchen		819
14 HSC16	Kitchen		820
15 HSC17	Kitchen		822
16 HSFPI8	Kitchen		825
17 HSFPI9	Serving Line		826
18 HSWC BF26	Cafeteria A		827
19 HSWC F20	Cafeteria A		829
20 HSWC BF21	Cafeteria B		831
21 HSWC F21	Cafeteria B		834
22 HSWC22	Outside VP office		836
23 HSWC 23	Outside Guidance		837
24 HSNS 24	Nurse Room		844
25 HSNS 25	Nurse Room		845
26 HSWC30	Outside VP 2nd Floor		850
27 HSS 31	Media Center		852
28 HSWC32	Outside Room 306		856
29 HSWC BF33	Outside Room 305		900
30 HSWC F33	Outside Room 305	↓	↓ 901

Method of Shipment

Sample Condition Upon Receipt:

Relinquished by

Date/Time

Received by

Date/Time

Relinquished by

Date/Time

Received by

Date/Time

Controlled Document - COC-25 Lead R17 05/08/2022



AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

EMSL Order Number / Lab Use Only

EMAIL: CinnaminsonLeadLab@gmail.com

012609434

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information.

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

High school

Controlled Document - COC-25 Lead R17 05/09/2022

☒

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

Page 2 of 2